



# CERTIFICATE

EC-Unit Verification  
for Modul G  
according Directive 97/23/EC

Certificate No.: 04 202 1 470 00 00290

Name and Address of  
Manufacturer:

Wilhelm Deller GmbH & Co. KG  
D-57078 Siegen

**Pressure Vessel**

Identification No: 32194

Drawing No: 00.1/32194

Piece list: -

Allowable Pressure Vessel min.: 0/7 bar  
Tube system min.: 0/7 bar

Component Heat exchanger 250 KW

Corrosion Allowance 1 mm for C-steel

Production facility Siegen-Sohlbach

Allowable Temperature Vessel 0-200 °C  
(min/max) Tube system 0-150 °C

Volume Vessel 100 l  
Tube system 64 l

**Hydrostatic Pressure Test**

Test Pressure Vessel 12,08 bar  
Tube system 10,62 bar

Date 14.09.2000  
Date 13.09.2000

It is hereby certified, that the results of the tests on the above mentioned pressure vessel fulfill the requirements of the

**Pressure Equipment Directive 97/23/EC**

The pressure vessel is marked with the following sign

**CE 0044**

Siegen, 10.10.2000  
Sü/Ka



TÜV CERT-Certification Body  
for Pressure Equipment of  
RWTÜV e.V.

Martin

Notified Body, Code 0044

RWTÜV e. V.  
Steubenstr. 53  
45138 Essen

Tel. ++49-201/825-2648  
Fax ++49-201/825-2502  
e-mail gnirss@rwtuev-at.de

Member of



CONFEDERATION EUROPEENNE D'ORGANISMES DE CONTRÔLE